

Marquee Bid # 180401
Questions & Answers
Batch 2

1. Do you have a design drawing of the Marquee?

No drawing design is available

2. How tall does the marquee need to be? I'm guessing at least 15' to see from the expressway?

As per bid scope requirements there is not a designated height. Sign must be visible from both sides of expressway North and Southbound.

3. Do you have electrical power run to the sign location? Will need separate circuits for the illuminated sign and LED displays FYI, The displays require too much power to make solar power cost effective

The administration office/building has electricity. Please feel free to conduct a site visit of the location so that you can determine the location you feel would be best for installation of marquee and determine if electricity needs to be "run". If this is the case, we would want for you to include costs of electrical connections in the bid.